



Control Number: 50594



Item Number: 30

Addendum StartPage: 0



Public Utility Commission of Texas

Five-Year Report

Required by 16 Texas Admin. Code § 25.97(e)



PROJECT NO. 50594

AFFECTED ENTITY: Big Country Electric Cooperative, Inc.

General Information

Pursuant to 16 Texas Admin. Code § 25.97(e)(1), not later than May 1 every five years, each affected entity that owns or operates overhead transmission facilities greater than 60 kilovolts must submit this report. The first report must be submitted not later than May 1, 2020.

Instructions

Answer all questions, fill-in all blanks, and have the report notarized in the Affidavit.

Affidavit

A representative of the affected entity must swear to and affirm the truthfulness, correctness, and completeness of the information provided by attaching a signed and notarized copy of the Affidavit provided with this form.

Filing Instructions

Submit four copies (an original and three copies) of the completed form and signed and notarized Affidavit to:

Central Records Filing Clerk
Public Utility Commission of Texas
1701 N. Congress Avenue
P.O. Box 13326
Austin, Texas 78711-3326
Telephone: (512) 936-7180

Affected Entity: Big Country Electric Cooperative, Inc.

PROJECT NO. 50594

1. Historical five-year reporting period: 01/01/2015 - 01/01/2020

What percentage of overhead transmission facilities greater than 60 kilovolts did you inspect for compliance with the National Electric Safety Code (NESC) relating to vertical clearance in the historical five-year reporting period?

Zero Percent of Big Country Electric Cooperative's overhead transmission facilities have been inspected for compliance with the National Electric Safety Code (NESC) relating to vertical clearance in the historical five-year reporting period.

Big Country Electric Cooperative has visually inspected 100% of its overhead transmission facilities over the historical five-year period, but past inspections did not included vertical clearance compliance documentation.

2. Future five-year reporting period: 01/01/2020 - 01/01/2025

What percentage of overhead transmission facilities greater than 60 kilovolts do you anticipate you will inspect for compliance with the NESC relating to vertical clearance during the future five-year reporting period beginning on January 1 of the year in which this report is submitted?

Big Country Electric Cooperative expects to inspect a 100 percent of its transmission facilities for compliance with the NESC relating to vertical clearance during the future five-year reporting period.

We expect to preform the wood pole inspections for the transmission system during this future five-year period.

Affected Entity: Big Country Electric Cooperative, Inc.

PROJECT NO. 50594

AFFIDAVIT

I swear or affirm that I have personal knowledge of the facts stated in this report or am relying on people with personal knowledge, that I am competent to testify to them, and that I have the authority to submit this report on behalf of the affected entity. I further swear or affirm that all statements made in this report are true, correct, and complete.

Robert Gandy
Signature

Robert Gandy
Printed Name

Vice President of Engineering
Job Title

Big Country Electric Cooperative, Inc.
Name of Affected Entity

Sworn and subscribed before me this 28 day of April, 2020.
Month Year

Sarah Johnson
Notary Public in and For the State of Texas

My commission expires on 02-27-2024

